

PERFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 01

Dated: 23/12/2024

It is certified that an inspection team headed by **Ankit Chauhan, Lab In charge, District Level Water Analysis Laboratory, Sitapur** (Name of officers with designation) from **UP Jal Nigam (Rural) Sitapur** (Name of Department/office) Inspected the **Seth Anandram Jaipuria School Sidhauri, Biswan Road, Puranpur, Sidhauri, Uttar Pradesh 261303** (Name & Address of the school) on **19-12-2024** (Date of inspection) and on the basis of water test report (Attached) Report no: **U2475508525505282** dated **21-12-2024** of **District Level Water Analysis Laboratory, Sitapur** (PHED) lab certified that the **Seth Anandram Jaipuria School, Sidhauri** (Name of school) has safe drinking water facilities for the students and member of staff of the institution. School is also maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central /state /U.T.Govt.

Note:

This certificate is valid till **01 Year** from date of issue. In case, if there is any change in Drinking Source /gone under maintenance before Expiry of certificate, then this certificate will be no more valid. So to avoid this problem School is advice to send Drinking Water Sample on Regular Interval to District Level Water Analysis Laboratory, Sitapur.

Signature with Seal.....


Executive Engineer
Division Office
UP Jal Nigam (Rural)
Sitapur

Name Rajeev Kumar Designation..... Executive Engineer

Name & Address of the office/Department

 **Arya Nagar Water Tank Sitapur**

To

Seth Anandram Jaipuria School**Biswan Road, Puranpur, Sidhauri, Uttar Pradesh 261303****(Name & Address of the institution)**



Analysis Report
District Level Water Analysis Laboratory
U.P Jal Nigam (Rural), SITAPUR, Uttar Pradesh, India
Address : Arya Nagar Water Tank , Sitapur



Rept No	U2475508S25505282	Date	23-12-2024	Page No.	1
URL No.	TC122252400000001F				
Custmor Name	Seth Anandram Jaipuriya School				

Basic details of sample

District	Sitapur	Block	Kasmanda
Gram Panchayat	Puranpur	Village/Mohalla	Puranpur
Habitation	Puranpur	Location/Site Name	On Roof Top
Water Source	RO	Sample No.	43809
Quantity of Sample	1L	Date of Sample Collection	19-12-2024
Receiving Date	19-12-2024	Sample Collector	By Client
Sample Depositer	By Client	Sampling Method	17614 Part 01
Analysis Start Date	19-12-2024	Analysis Completion Date	21-12-2024

Technical Data of Analysis

S.No.	Analysed Parameter	Units	Observed Value	Specified Values as per IS 10500:2012		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	2	3	4	5	6	7
1	pH @25°C	-	7.65	6.5-8.5	6.5-8.5	IS 3025 (Part 11) : 2022
2	Turbidity	(NTU)	0.41	1	5	IS 3025 (Part 10) : 2023
3	TDS	(mg/L)	200	500	2000	IS 3025 (Part 16) : 2023
4	Chloride	(mg/L)	10	250	1000	IS 3025 (Part 32) : 2019
5	Total Alkalinity	(mg/L)	112	200	600	IS 3025 (Part 23) : 2023
6	Total Hardness	(mg/L)	96	200	600	IS 3025 (Part 21) : 2019
7	Calcium	(mg/L)	11.19	75	200	IS 3025 (Part 40) : 2023
8	Magnesium	(mg/L)	16.52	30	100	IS 3025 (Part 46) : 2023
9	Sulphate	(mg/L)	0.00	200	400	APHA 24 Edition -4500 S04 method (Turbidity method):2023
10	Nitrate	(mg/L)	0.13	45	45	APHA 24 Edition -4500 NO3 method B (UV Spectrophotometric method):2023
11	Fluoride	(mg/L)	0.17	1	1.5	APHA 24 Edition -4500-F Method C (Electrode Method) : 2023
12	Iron	(mg/L)	0.0	1	No relaxation	APHA 24 Edition -3500-Fe Method B (Phenanthroline Method) : 2023
13	Color	Hazen	<5	5	15	IS 3025 (Part 4) : 2021
14	Conductivity	µs/cm	328	N/A	N/A	IS 3025 (Part 14) : 2013

Note

1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 07 days (in case of non perishable items only) from the date of issue of tests reports unless otherwise specified.

Authorized Signatory

Prepared By

Chemist
Ankit Chauhan

Laboratory Contact details :- Email - stplabupjalnigam@gmail.com , Mob :- +91 8979986782

End of the report



Analysis Report
District Level Water Analysis Laboratory
U.P Jal Nigam (Rural), SITAPUR, Uttar Pradesh, India

Rept No	U2475500525505282	Date	23-12-2024	Page No.	1
Custmor Name	Seth Anandram Jaipuriya School				

Basic details of sample

District	Sitapur	Block	Kasimanda
Gram Panchayat	Puranpur	Village/Mohalla	Puranpur
Habitation	Puranpur	Location/Site Name	On Roof Top
Water Source	RO	Sample No.	43899
Quantity of Sample	1L	Date of Sample Collection	19-12-2024
Receiving Date	19-12-2024	Sample Collector	By Client
Sample Depositer	By Client	Sampling Method	17614 Part 01
Analysis Start Date	19-12-2024	Analysis Completion Date	21-12-2024

Technical Data of Analysis


S.No.	Analysed Parameter	Units	Observed Value	Specified Values as per IS 10500:2012		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	2	3	4	5	6	7
2	E.coli	-	0.0	Shall Not Be Deducted In 100 ml sample		APHA 23rd Edition -9211B
3	T.coli	-	0.0	Shall Not Be Deducted In 100 ml sample		APHA 23rd Edition -9211B
4	Total Arsenic	(mg/L)	0.0	0.01	No Relaxation	IS 3025 (Part 37):1988

Note

1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 07 days (in case of non perishable items only) from the date of issue of tests reports unless otherwise specified.

Authorized Signatory


Prepared By
Microbiologist


Chemist
Ankit Chauhan

Laboratory Contact details -: Email - stplabupjalnigam@gmail.com , Mob -: +91 8979986782

End of the report